



Florida Department of Transportation

CHARLIE CRIST
GOVERNOR

1109 S. Marion Avenue
Lake City, Florida 32025

STEPHANIE C. KOPELOUSOS
SECRETARY

June 22, 2009

To: Prospective Bidders

**Addendum No: 1, E2N70, Financial Project #41801235201
St. Augustine Maintenance Warehouse HVAC Replacement**

Questions and Answers:

(1) As part of alternate #1, would the owner want the cabinet of the condensing unit coated as well as the coils?

ANSWER: No, coating of the cabinet will not be required.

(2) Will test and balance be required as part of the bid?

ANSWER: No, the only testing that is required for this project will be to ensure that the new condensing and air handling units are set up and working properly.

You must sign, date and fax a copy of this addendum back to me by close of business today to indicate receipt. A copy of this addendum must be returned with your bid.

Company Name

Signature

Date

Thanks,

Patsy Elkins
Contracts Coordinator
Phone: 386-758-3703
Fax: 386-758-3791